

## Construction Stormwater Permit Common Violations

- Failure to apply for coverage under permit
- Failure to post Notice of Intent (NOI), Permit Notice, etc. or have SWPP Plan and Permit present (depends on permit requirements)
- Inadequate SWPP Plan
  - Not site-specific
  - Maps do not show all items required by permit
  - Erosion and Sediment (E&S) Controls changed but the SWPPP Narrative or Plans have not been updated.
- Failure to implement E&S controls on SWPP Plan or required by permit
- Failure to maintain E&S controls
  - Concrete Washout
  - Stabilized Construction Entrance
  - Secondary Containment
  - Perimeter Controls
  - Inlet Protection Barriers
- Stormwater inspector not qualified
- Stormwater inspections not conducted or documented

